

INTER-OFFICE MEMORANDUM

To: Subcode Official for ADA
Wayne Environmental Commission (WEC)
Fire Bureau
Fire Commissioner
Health Department
Planner
Superintendent of Water & Sewer
Supervisor of Landscape and Park Design

From: Kathleen Miesch
Planning Coordinator

Date: December 6, 2019

Subject: Planning Board Case #PB-2019-034
Scheduled for January 13, 2019
910 Hamburg Turnpike
Block 3103, Lot 2; District B
Amended Preliminary and Final Site Plan
910 Hamburg Turnpike, LLC

Attached please find the following documents:

- Application form
- Stormwater Management Report signed and sealed by Menlo Engineering Assoc., dated 8-29-2018 last revised 9-27-2019 (Engineering & Water and Sewer only)
- Proposed Retail Center signed and sealed by The Dietz Partnership dated 1-25-2019 last revised 11-26-2019
- Prelim and Final Site Plan page 4 of 23 signed and sealed by Menlo Engineering dated 10-18-2018 last revised 4-12-2019
- Prelim and Final Site Plan signed and sealed by Menlo Engineering dated 8-29-2018 last revised 11-25-2019

Please review the package and provide your comments by
12-31-2019 for distribution in Board packets
Reviewer's Response (*use additional sheet if necessary*):

The "Storz" connection shown on sheet 17 is not correct. The "Storz" connection is an integral fitting on the hydrant, not a separate fixture.

Heather Vitz-Del Rio

12/20/19

Name

Date