


**INTER-OFFICE MEMORANDUM**

**To:** Subcode Official for ADA  
Wayne Environmental Commission (WEC)  
Fire Bureau  
Fire Commissioner  
Health Department  
Planner  
Superintendent of Water & Sewer  
Supervisor of Landscape and Park Design

**From:** Kathleen Miesch  
Planning Coordinator

**Date:** December 6, 2019

**Subject:** Planning Board Case #PB-2019-034  
**Scheduled for January 13, 2019**  
910 Hamburg Turnpike  
Block 3103, Lot 2; District B  
Amended Preliminary and Final Site Plan  
910 Hamburg Turnpike, LLC



Attached please find the following documents:

- Application form
- Stormwater Management Report signed and sealed by Menlo Engineering Assoc., dated 8-29-2018 last revised 9-27-2019 (Engineering & Water and Sewer only)
- Proposed Retail Center signed and sealed by The Dietz Partnership dated 1-25-2019 last revised 11-26-2019
- Prelim and Final Site Plan page 4 of 23 signed and sealed by Menlo Engineering dated 10-18-2018 last revised 4-12-2019
- Prelim and Final Site Plan signed and sealed by Menlo Engineering dated 8-29-2018 last revised 11-25-2019

Please review the package and provide your comments by  
**12-31-2019** for distribution in Board packets  
Reviewer's Response (*use additional sheet if necessary*):

THE WEC OBJECTS TO ANY INCREASE IN THE IMPERVIOUS COVERAGE,  
PERVIOUS PAVING SHOULD BE USED TO REDUCE THE IMPERVIOUS  
SURFACE TO THE 70% REQUIRED.

RICHARD STOMBER

Richard Stomber

Name

Date

12/23/2019