

**INTER-OFFICE MEMORANDUM**

**To:** Subcode Official for ADA  
Wayne Environmental Commission (WEC)  
Fire Bureau  
Fire Commissioner  
Fire Chief  
Health Department  
Planner  
Superintendent of Water & Sewer  
Supervisor of Landscape and Park Design

**From:** Kathleen Miesch  
Planning Coordinator

**Date:** December 14, 2021

**Subject:** Case #PB-2021-018  
**Scheduled January 24, 2022**  
**46 Route 46; Block 219, Lot 1**  
**46 Route 46, LLC**  
**Minor Site Plan**

---

Attached please find the following documents:

- Survey prepared by Schwanewede/Hals Engineering dated February 17, 2021; last revised May 28, 2021
- Site Plan prepared by Schwanewede/Hals Engineering dated June 3, 2021
- Architectural Plan prepared by SEMAC Design Group dated February 22, 2020; last revised December 6, 2021
- Application signed by owner/applicant dated June 18, 2021

Please review the package and provide your comments by January 11, 2022 for distribution in Board packets.

Reviewer's Response (*use additional sheet if necessary*):

---

Dumpster to be a minimum of 15 feet from the building.

---

---

---

Richard Boonstra, Fire Official

January 11, 2022

*Name*

*Date*